



---

Mechanical Engineering Consultants | HVAC & Plumbing

**Mechanical Addendum #1**

TO: Kevin Genzlinger  
FROM: Jon Giles, PE  
DATE: 7-30-18  
RE: Platte Airport  
Platte, SD

---

The following addendum items shall become a binding part of the contract documents and shall be included as part of the contract price:

**General:**

1. Provide hose reel for 50' of hose.
2. 1 ½" pipe to be provided as 2" pipe. Pipe to be above ground; contractor to verify acceptance with AHJ.
3. Provide solenoid valve is required for system. Supplier to provide complete package.
4. Holding tank is for future building sewer.

**Product Approvals:**

<u>Spec Section</u>	<u>Product Description</u>	<u>Manufacturer</u>
Drawings	700 series dispenser	Gilbarco
	8800K dispenser	
	Pumps	Gasboy

**End of Addendum**