

July 26, 2019

Re: Snow Removal Equipment (SRE) Storage Building  
Rosebud Sioux Tribal Airport  
Rosebud, South Dakota  
AIP #3-46-0082-011-2019  
Helms #A-7146

Bid Opening: **July 30, 2019**  
**2:00 pm Local Time**

**ADDENDUM NUMBER 1**

The following modifications are made to the plans and specifications for the Snow Removal Equipment (SRE) Storage Building, Rosebud Sioux Tribal Airport:

**PLANS**

**1. Sheet C9, Project Layout Plan, add the following note:**

The concrete approach pavement shall be 6" thick. The dimensions of the concrete approach will be approximately 7.2' x 48' to match into existing concrete apron and approach pavement of existing SRE building. Silicone Joint Sealing Filler w/Expansion board shall be installed where the proposed approach pavement meets the existing concrete apron. See structural plans for connection to proposed building.


The contractor shall provide 12" compacted aggregate base course below concrete approach pavement. This shall conform to the requirements of the 2015 Edition of the South Dakota Transportation Standard Specifications for Roads and Bridges, Section 882, Aggregates for Granular Bases and Surfacing. The aggregate base course shall be furnished, placed and compacted under the concrete approach pavement. The moisture content of aggregate base course during placing operations shall be within  $\pm 2$  percent of optimum moisture content and shall be compacted to not less than 97 percent of maximum density as determined by ASTM D 698. The in-place field density shall be determined in accordance with ASTM D 1556, ASTM D 2167, or ASTM D 6938.

**CLARIFICATION:**

**Garage Doors:**

The Raynor ThermaSeal TM220 door (20 gauge exterior / 26 gauge interior) is an acceptable garage door.

**ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED**



BY: \_\_\_\_\_

PROJECT ENGINEER – HELMS & ASSOCIATES

**Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.**