



CIVIL ENGINEERS & LAND SURVEYORS

416 N. Production St.
P.O. Box 111
Aberdeen, SD 57402

Phone: (605) 225-1212 Fax: (605) 225-3189
Email: operations@helmsengineering.com

March 13, 2024

Re: Water System Improvements
Wessington, South Dakota
A-8570

Bid Opening: **Friday, March 15, 2024**
11:00 am Local Time

ADDENDUM NUMBER 1



The following modifications become a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgement of the addendum on his bid form, incorporating its provisions in his bid.

CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS

1. PART 2, DIVISION 33 00 00, Section 33 01 10.71: *Strikeout 3.01 K*

2. CLARIFIACATION: *Residents of Wessington shall not be without water for more than a period of six (6) hours per day. Written notification 48 hours in advance is needed for coordination with residents.*

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED

BY:  

The seal is circular with a dotted border. The outer ring contains the text "Registered Professional Engineer". The inner circle contains the text "REG. No. 11937 BRANDON D. MID SOUTH DAKOTA".

PROJECT ENGINEER – HELMS & ASSOCIATES

Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.