

July 26, 2019

Re: Runway 12/30 Reconstruction
Wessington Springs Municipal Airport
Wessington Springs, South Dakota
AIP # 3-46-0080-011-2019
A-6797

Bid Opening: **July 30, 2019**
2:00 pm Local Time


ADDENDUM NUMBER 1

The following modifications are made to the plans and specifications for the Runway 12/30 Reconstruction, Wessington Springs Municipal Airport:

CLARIFICATION

1. There is existing underdrain piping approximately 2'-3' from the edge of the runway (both sides) at a depth of approximately 22"-24". This pipe will be removed and disposed of as part of the Unclassified Excavation. No additional measurement or payment will be made for the removal and disposal of the existing underdrain piping.

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED



BY: _____

PROJECT ENGINEER, HELMS & ASSOCIATES

Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.