

July 28, 2025

Re: Aberdeen Water Tower and Transmission Line  
Aberdeen, South Dakota  
SRF # C462072-04  
EDA# 05-79-06091  
Helms # 8542

Bid Opening: **July 29, 2025**  
**2:00 pm (local time)**

**ADDENDUM NUMBER 2**

The following modifications are made to the plans and specifications for the Aberdeen Water Tower and Transmission Line Project.

**CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS**

**1. Section 33 11 00 Water Utility Piping and Fittings; Part 1.04F (see addendum #1): add the following paragraph;**

In lieu of LDPE caps and plugs for transport and storage, contractor may have the pipes wrapped sufficiently to limit intrusion of dirt and debris. Contractor shall use caps or plugs for staging and installation to limit intrusion of dirt, debris and water. Contractor shall have a minimum of 24 pipe able to be temporary capped and plugged.

**PLANS:**


SHEET 6: Asphalt Trench Repair Detail: Add the following Note: *For 6" nominal asphalt pavement thickness the contractor shall install in three-2" compacted lifts.*

**ATTACHEMENTS:**

ELECTRICAL ADDENDUM

BY: 

PROJECT ENGINEER – HELMS & ASSOCIATES



**Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.**

ADDENDUM NO. 2  
TO  
CONTRACT DOCUMENTS, DRAWINGS, AND SPECIFICATIONS FOR  
THE CITY OF ABERDEEN, SOUTH DAKOTA  
WATER TOWER AND TRANSMISSION LINE

EDA No. 05-79-06091  
SRF No. C462072-04  
Helms Project No. A-8542  
HDR Project No. 10330662

DATE OF ISSUE: July 28, 2025

**TO: PROSPECTIVE BIDDERS AND OTHER INTERESTED PARTIES**

**Addendum No. 2 is being sent out to all plan holders.**

THE CONTRACT DOCUMENTS AND SPECIFICATIONS, INCLUDING THE CONTRACT DRAWINGS ARE HEREBY MODIFIED BY THE FOLLOWING ITEMS:

**CHANGES TO DRAWINGS**

**AD-2 ITEM 1: DRAWING E5 – ELECTRICAL DETAILS.**


1. On Drawing E5, delete Detail 5.
2. On Drawing E5, add the following to Detail 6. “Note: Ground fence at two locations adjacent to where utility secondary crosses under the fence.”

**ALL ITEMS IN CONFLICT WITH THE ADDENDA ARE HEREBY DELETED.**

THIS ADDENDUM IS MADE PART OF THE CONTRACT DOCUMENTS AND SHALL BE NOTED IN THE PROPOSAL FORM.

HDR Engineering, Inc.

Kyle Ganskop, PE  
Senior Electrical  
Engineer



**END OF ADDENDUM NO. 2**