

April 21, 2026

Re: Partial Parallel Taxiway Phase II  
 Huron Regional Airport  
 Huron, South Dakota  
 AIP #3-46-0052-046-2026  
 Helms #A-8709

Bid Opening: **April 23<sup>rd</sup>, 2026**  
**2:00 pm Local Time**

**ADDENDUM NUMBER 2**

The following modifications are made to the plans and specifications for the Partial Parallel Taxiway Phase II Project, Huron Regional Airport.

**\*Mobilization is limited to 10 percent of the total project cost.\***

**Contract Documents and Technical Specifications**

**1. Technical Specifications, Item P-208 Aggregate Base Course, page 153. The following shall replace the Gradation of Aggregate Base:**


**Gradation of Aggregate Base**

<b>Sieve Size</b>	<b>Design Range Percentage by Weight passing</b>	<b>Contractor's Final Gradation</b>	<b>Job Control Grading Band Tolerances for Contractor's Final Gradation<sup>1</sup> Percent</b>
1 inch (25.0 mm)	100		±8
3/4 inch (19.0 mm)	80-100		±8
1/2 inch (12.5 mm)	68-91		±8
No. 4 (4.75 mm)	46-70		±8
No. 8 (2.36 mm)	34-58		±8
No. 40 (425 µm)	13-35		±5
No. 200 (75 µm)	3.0-12.0		±3

**Clarifications**

**The PAPI 18 circuit under the proposed Taxiway B at +/- Sta. 9+20 should be denoted as Sand-Encased Sch. 80 Conduit.**

**ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED**



BY: \_\_\_\_\_

PROJECT ENGINEER – HELMS & ASSOCIATES

**Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.**