



416 N. PRODUCTION ST.
ABERDEEN, SD 57401
PHONE: (605) 225-1212

June 13, 2024

Re: Henry Water System Improvements
Henry, South Dakota
A-9292

Bid Opening: **June 17, 2024**
3:00 pm Local Time

ADDENDUM NUMBER 1

The following modifications become a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgement of the addendum on his bid form, incorporating its provisions in his bid.

CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS

1. PART 2 CONSTRUCTION REQUIREMENTS, SECTION 33 12 13, 2.04 D- *Use the attached Bid Form which adds in an item for Temporary Water.*

2. PART 2 CONSTRUCTION REQUIREMENTS, SECTION 33 11 00, 2.03 A- *shall be replaced with the following: "All 4", 6" and 8" Polyvinyl Chloride pipe shall be pressure class 235 (DR18) AWWA C 900 rated pipe with rubber gasket sealed joints. All 2" Polyvinyl Chloride pipe shall be Schedule 40, SDR-18 and shall conform to this section."*

3. PART 2 CONSTRUCTION REQUIREMENTS, SECTION 33 12 13, 2.04 D- *Remove entire Section D. The curb stop box does not need a tracer wire screw on bottom as it will terminate in the box.*

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED

BY:  

PROJECT ENGINEER – HELMS & ASSOCIATES

Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.

**Water System Improvements
Helms Project No. A-9292**

BASE BID- BID FORM					
Item #	Item Description	Quantity	Unit	Unit Price	Total Price
1	Mobilization	1	L.S.	Lump Sum	\$
2	Remove & Dispose Gate Valve	8	Each	\$	\$
3	Remove & Salvage Fire Hydrant	7	Each	\$	\$
4	Remove & Replace Concrete Sidewalk	2,101	Sq.Ft.	\$	\$
5	Remove & Replace Concrete Surfacing	516	Sq.Ft.	\$	\$
6	Remove & Replace Concrete Curb & Gutter	155	Ft.	\$	\$
7	Remove & Replace Concrete Header Curb	30	Ft.	\$	\$
8	Remove & Replace Concrete Valley Gutter	40	Sq.Ft.	\$	\$
9	Storm Sewer Repair	89	Ft.	\$	\$
10	6" Watermain	5,355	Ft.	\$	\$
11	Watermain Casing	140	Ft.	\$	\$
12	Connect to Existing Watermain	11	Each	\$	\$
13	6" MJ Gate Valve w/ Box	22	Each	\$	\$
14	6" 90° MJ DI Bend	4	Each	\$	\$
15	6" MJ DI Tee	12	Each	\$	\$
16	6" MJ DI Cross	1	Each	\$	\$
17	4" x 6" Reducer	11	Each	\$	\$
18	6" Cap	3	Each	\$	\$
19	Fire Hydrant w/ Steamer	7	Each	\$	\$
20	6" Saddle w/ 1" Corp	52	Each	\$	\$
21	1" Water Service Line	2,583	Ft.	\$	\$
22	1" Curb Stop	52	Each	\$	\$
23	Connect to Existing Water Service	54	Each	\$	\$
24	Asphalt Street Repair (3" Nominal Depth)	580	Tons	\$	\$
25	Gravel Street Repair (6" Nominal Depth)	574	Tons	\$	\$
26	Granular Base Course (8" Nominal Depth)	1,424	Tons	\$	\$
27	Pipe Bedding	620	Tons	\$	\$
28	Rock Bedding	100	Tons	\$	\$

BASE BID- BID FORM CONTINUED

Item #	Item Description	Quantity	Unit	Unit Price	Total Price
29	Contaminated Soil Removal and Disposal	100	C. Y.	\$	\$
30	Exploratory Excavation	20	Hours	\$	\$
31	Temporary Water	1	L.S.	Lump Sum	\$
32	Traffic Control	1	L.S.	Lump Sum	\$
33	Storm Water Pollution Prevention Plan	1	L.S.	Lump Sum	\$
34	Seeding, Fertilizing, and Mulching (Lawn)	1	Acres	\$	\$
Total Base Bid				\$	
Written					Dollars

ALL ITEMS FURNISHED AND INSTALLED