

April 23, 2024

**RE: WATER STORAGE IMPROVEMENTS
MILLER, SOUTH DAKOTA
SPN #16085**

BID LETTING: TUESDAY, APRIL 30, 2024 @ 3:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the plans and specifications for the Water Storage Improvements Project.

Section C-410 Bid Form:

Replace Page 2 of 6 of the Bid Form with the updated version attached to this addendum. The changes to the Bid Form are as described below:

- An optional deduction is added to represent the cost savings if one bidder was awarded both bid schedules.
- A summary of the bid schedules with the optional deduction is added.

Section 33 16 23, Ground Storage Tank Improvements:

Paragraph 1.02 A:

Note that the glass lined steel floor shall be included in the recoat project. The floor coating shall be protected as much as possible and repaired if damaged.

Paragraph 1.02 C shall be replaced with the following:

C. The two existing magnesium bars shall be removed. Four magnesium anode bars shall be furnished and installed for continued cathode protection. A cathodic testing bulkhead shall be furnished and installed.

Paragraph 2.01 / 2.02:

Note that the sealants shall be black.


Paragraph 2.03 D:


Note that bolt replacement is not expected; however, if they are replaced, they should be encapsulated as specified.

Paragraph 2.03 I shall be replaced with the following:

Existing bolt caps on the interior floor can be removed and not reinstalled. Bolt caps on the exterior do not exist and will not be added.

All other items of the plans and specifications remain unchanged.


Camden A. Hofer, Project Engineer
Schmucker, Paul, Nohr & Associates



The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the *MILLER WATER STORAGE IMPROVEMENTS*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.

NOTE: Bidder is instructed to bid one or both bid schedules. A separate Contract is expected for each bid schedule. If bidding both bid schedules, the bidder may provide an optional deduction below, if applicable.

**Water Storage Improvements
Miller SD
SPN #16085**

BID SCHEDULE A: Ground Storage Tank

Item	Description	Quantity	Unit Cost	Total Cost
1	Mobilization	1 LS	\$	\$
2	Interior Reseal	1 LS	\$	\$
3	Exterior Reseal	1 LS	\$	\$
4	Reseal Node Covers on Dome and Vent	1 LS	\$	\$
5	Overcoat Overflow Pipe	1 LS	\$	\$
6	Cathodic Anode Bars and Testing Bulkhead	1 LS	\$	\$
Total for Bid Schedule A				\$

BID SCHEDULE B: Tank Mixers

1	Furnish and Install Mixer in Water Tower	1 LS	\$	\$
2	Furnish and Install Mixer in Ground Storage Tank	1 LS	\$	\$
Total for Bid Schedule B				\$

Optional Deduction for Bid Schedules A and B				\$
---	--	--	--	-----------

Total for Bid Schedules A and B with Deduction				\$
---	--	--	--	-----------