

May 13, 2024

Re: Mitchell Landfill Recycling Building  
Mitchell, South Dakota  
Helms Project # A-8033  
**Bid Date: 5/14/2024**

**ADDENDUM NUMBER 2**

The following modifications are made to the plans and specifications for the Mitchell Landfill Recycling Building Project.

**CIVIL CONSTRUCTION SPECIFICATIONS AND CONTRACT DOCUMENTS**

NONE

**PLANS**

NONE

**APPROVALS:**

Septic Tank: MI-1060 Tank as manufactured by Infiltrator Water Technologies

**ATTACHEMENTS:**

ARCHITECTURAL ADDENDUM #2

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED.

BY *Leif C. Redinger*  
PROJECT ENGINEER - HELMS AND ASSOCIATES



FIRM NAME: \_\_\_\_\_ BY: \_\_\_\_\_

TITLE: \_\_\_\_\_ DATE: \_\_\_\_\_

ATTACH THIS SIGNED ADDENDUM TO THE BID FORM WHEN SUBMITTING AND/OR ACKNOWLEDGE THE ADDENDUM ON THE BID FORM.

ADDENDUM NO.2  
PLAN CLARIFICATIONS  
TO GENERAL, STRUCTURAL, MECHANICAL AND ELECTRICAL  
LANDFILL RECYCLING BUILDING  
MITCHELL REGIONAL LANDFILL  
MITCHELL, SOUTH DAKOTA

Addendum Plan Clarifications Dated: May 13, 2024

Original Plans and Specifications Dated: November 3, 2023 / April 12, 2024

NOTE: The Plans, details and accompanying specifications shall be amended as follows, but where any article is amended the original article shall remain in effect and shall become a part of the original plans and specifications.

A. PLAN CHANGES AND CLARIFICATIONS:

1. Sheet A3: W1 EXTERIOR WALL

a) Delete interior 6 Mil. Vapor Barrier.

2. Sheet S1: FOUNDATION PLAN

a) Gridline 2 should match location shown on Detail 7/S2.

3. Sheet S3: SECTIONS AND DETAILS

a) Detail 7/S2. There is an elevation change from 85'-0" to 96'-6", 9" east of the gridline.

B. SPECIFICATIONS:

1. SECTION 13 34 19 – METAL BUILDING SYSTEMS

A. 1.4 System Description, C. End-Wall Framing: West elevation does not need expandable endwall.

HKG ARCHITECTS, INC., ARCHITECTS, AIA, ABERDEEN, SD