

January 30, 2023

**RE: Sanitary Sewer Improvements
Plankinton, South Dakota
SPN #16107**

BID LETTING: Thursday, February 2, 2023 @ 2:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the plans and specifications for the Sanitary Sewer Improvements Project.

Section 33 01 30.72, Cured-in-Place Pipe Lining:

Paragraph 3.03 A. 2: Add the following after the last sentence:

Either air or water inversion is acceptable.

Paragraph 3.03 A. 3: Add the following after the last sentence:

Either steam or water curing is acceptable.

All other items of the plans and specifications remain unchanged.

Camden A. Hofer, Project Engineer
Schmucker, Paul, Nohr & Associates



The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the *Plankinton Sanitary Sewer Improvements Project*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.