

October 11, 2024

**RE: WATER STORAGE IMPROVEMENTS
PLATTE, SOUTH DAKOTA
SPN #16367**

BID LETTING: TUESDAY, OCTOBER 15, 2024 @ 3:00 PM

ADDENDUM NUMBER 2

The following modifications are to be made to the plans for the Water Storage Improvements Project.

Page 1 of 2:

The portion of pit welding and plate repair shall be on the area shown and an assumed area of ¼ of the floor area. Revise the area of pit welding and plate repair to approximately 1,160 square feet.

All other items of the plans and specifications remain unchanged.



The undersigned hereby acknowledges receipt of Addendum Number 2 to the plans for the *PLATTE WATER STORAGE IMPROVEMENTS*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 2 TO THE BID FORM WHEN SUBMITTING.