

January 12, 2024

Re: Lake Platte Levee Repair
Platte, South Dakota
SPN Project # M-15626
Bid Date: 1/25/2024

ADDENDUM NUMBER 1

The following modifications are made to the plans and specifications for the Lake Platte Levee Repair Project

CIVIL CONSTRUCTION SPECIFICATIONS AND CONTRACT DOCUMENTS

1. Section 31 23 00 Excavation and Fill, Part 2.01; add the following paragraph

D. A new facility permitted for the sole purpose of furnishing borrow material for the project will not be considered an approved source regardless of State or SHPO approval documentation. Contractor shall utilize an existing permitted facility and provide the documentation requirements of paragraph "C" prior to placement of any borrow material. Any material provided from a non-approved source shall not be allowed, regardless of cost. The South Dakota DANR maintains a database for existing facilities and can be used as resource for sourcing the borrow material. Contractor can utilize the Construction Aggregate & Mining Map link found on the following web page. <https://danr.sd.gov/Press/DataAndMapping.aspx>. Contractor shall be responsible for furnishing the required documentation regardless of the status of the source site shown on the DANR website.

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED.



BY Leif C. Redinger
PROJECT ENGINEER - HELMS AND ASSOCIATES/SPN & Associates
=====

FIRM NAME: _____ BY: _____

TITLE: _____ DATE: _____

ATTACH THIS SIGNED ADDENDUM TO THE BID FORM WHEN SUBMITTING AND/OR ACKNOWLEDGE THE ADDENDUM ON THE BID FORM.