



416 N. PRODUCTION ST.
ABERDEEN, SD 57401
PHONE: (605) 225-1212

June 13, 2024

Re: Raymond Water System Improvements
Raymond, South Dakota
A-9386

Bid Opening: **June 18, 2024**
1:00 pm Local Time

ADDENDUM NUMBER 1

The following modifications become a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgement of the addendum on his bid form, incorporating its provisions in his bid.

CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS

1. PART 1 BIDDING AND CONTRACT DOCUMENTS, SECTION 00 21 13, *Strikeout paragraphs 26.03, 28.03, & 30.01.* This project is not funded with Build America, Buy America funds.

2. BIDDING DOCUMENTS SECTION 00 41 00, 3.01, Item 19- *Strike Out "Furnish &".* The owner will furnish meter pits to be installed. The excise tax will be calculated on this item after the bid. The tax will be reimbursed through the project.

3. PART 2 CONSTRUCTION REQUIREMENTS, SECTION 33 11 00, 2.03 A- *shall be replaced with the following:* "All 4", 6" and 8" Polyvinyl Chloride pipe shall be pressure class 235 (DR18) AWWA C 900 rated pipe with rubber gasket sealed joints. All 2" Polyvinyl Chloride pipe shall be Schedule 40, SDR-18 and shall conform to this section."

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED

BY:  

PROJECT ENGINEER – HELMS & ASSOCIATES

Acknowledge receipt of the Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as above.